










USER SKIDS ROUNDS

DATE: 2/21/2003 TIME: _____ TECH: _____

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4	115	N/A	Good	Good	0	1	N/A	16.97	N/A	
SRI-CAT SECTOR 2 SRVC 5/6	Off line	N/A	Good		N/A	N/A	N/A	N/A	N/A	
SRI-CAT SECTOR 3/4 SRVC 7/8	135	58	Good	Good	0	0	16.16	15.59	N/A	
MU-CAT SECTOR 6 CL 82	125	5.6	Good	Good	0	0	17.14	16.14	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	90	N/A	Good		0	0	9.37	8.44	N/A	
IMM-CAT SECTOR 8 CL 88	70	15.1	Good	Good	0	0	14.15	13.56	N/A	
CMC-CAT SECTOR 9 SRVC 11/12	130	48.8	Good	Good	0	0	20.89	15.66	N/A	
BESSRC-CAT SECTOR 11 SRVC 13/14	80	72	Good		0	N/A	N/A	N/A	N/A	
SECTOR 15 SRVC 17/18	80	27	Good	Good	0	0	5.27	5.27	N/A	
SBC-CAT SECTOR 19 SRVC 21/22	30	72	Good		0	0	N/A	N/A	67	
SER-CAT SECTOR 22 CL130	50	60	Good		0	N/A	N/A	N/A	60	N/A
SGX-CAT SECTOR 31 SRVC 33/34	N/A	127	Good		0	N/A	N/A	N/A	N/A	
SECTOR 32 CL 160	150	N/A	Good		0	0	23.04	17.1	N/A	
UNI-CAT SECTOR 33 SRVC 35/36	120	N/A	Good		N/A	0	7.92	7.73	N/A	
SECTOR 34 CL 166	145	134	Good		N/A	0	N/A	16.05	N/A	