










USER SKIDS ROUNDS

DATE: 3/14/2003 TIME: _____ TECH: _____

| CAT NAME/ LOCATION | PUMP DISCHARGE OR SYSTEM PRESSURE | SYSTEM FLOW RATE | SYSTEM LEVEL/ FILL | N2 PRESSURE | SYSTEM FILTER DP | POLISHING FILTER DP | POLISHING RESISTIVITY | SYSTEM RESISTIVITY | SUPPLY TEMP. | UV |
|----------------------------------------------|-----------------------------------------|------------------------|--------------------------|-------------------------------------------------------------------------------------|------------------------|---------------------------|--------------------------|-----------------------|-----------------|-----|
| SRI-CAT SECTOR 1 SRVC 3/4 | 115 | N/A | Good | Good | 0 | 1 | N/A | 17 | N/A | |
| SRI-CAT SECTOR 2 SRVC 5/6 | Off line | N/A | Good |  | N/A | N/A | N/A | N/A | N/A | |
| SRI-CAT SECTOR 3/4 SRVC 7/8 | 135 | 57.6 | Good | Good | 0 | 0 | N/A | 15.24 | N/A | |
| MU-CAT SECTOR 6 CL 82 | 125 | 5.6 | Good | Good | 0 | 0 | 16.06 | 15.8 | N/A | |
| MHATT-CAT SECTOR 7 SRVC 9/10 | 90 | N/A | Good |  | 0 | 0 | 8.63 | 7.88 | N/A | |
| IMM-CAT SECTOR 8 CL 88 | 70 | 15.5 | Good | Good | 0 | 0 | 14.92 | 14.03 | N/A | |
| CMC-CAT SECTOR 9 SRVC 11/12 | 125 | 49 | Good | Good | 0 | 0 | 20.75 | 15.67 | N/A | |
| BESSRC-CAT SECTOR 11 SRVC 13/14 | 80 | 72.9 | Good |  | 0 | N/A | N/A | N/A | N/A | |
| SECTOR 15 SRVC 17/18 | 80 | 26.8 | Good | Good | 0 | 0 | 5.8 | 5.5 | N/A | |
| SBC-CAT SECTOR 19 SRVC 21/22 | 35 | 72 | Good |  | 0 | 0 | N/A | N/A | 67 | |
| SER-CAT SECTOR 22 CL130 | 48 | 60 | Good |  | 0 | N/A | N/A | N/A | 60 | N/A |
| SGX-CAT SECTOR 31 SRVC 33/34 | 70 | 12.39 | Good |  | 0 | N/A | N/A | N/A | N/A | |
| SECTOR 32 CL 160 | 160 | N/A | Good |  | 0 | 0 | 22.76 | 17 | N/A | |
| UNI-CAT SECTOR 33 SRVC 35/36 | 120 | N/A | Good |  | N/A | 0 | 7.64 | 7.53 | N/A | |
| SECTOR 34 CL 166 | 145 | 134 | Good |  | N/A | 0 | N/A | 15.94 | N/A | |