










USER SKIDS ROUNDS

DATE: 3/17/2003 TIME: _____ TECH: _____

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4	118	N/A	Good	Good	0	1	N/A	17.07	N/A	
SRI-CAT SECTOR 2 SRVC 5/6	Off line	N/A	Good		N/A	N/A	N/A	N/A	N/A	
SRI-CAT SECTOR 3/4 SRVC 7/8	135	57.5	Good	Good	0	0	N/A	14.96	N/A	
MU-CAT SECTOR 6 CL 82	130	8.1	Good	Good	0	0	17	15.96	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	85	N/A	Good		0	0	9.28	8.25	N/A	
IMM-CAT SECTOR 8 CL 88	70	15.4	Good	Good	0	0	15.1	19.94	N/A	
CMC-CAT SECTOR 9 SRVC 11/12	125	49	Good	Good	0	0	20.88	15.3	N/A	
BESSRC-CAT SECTOR 11 SRVC 13/14	80	72	Good		0	N/A	N/A	N/A	N/A	
SECTOR 15 SRVC 17/18	80	26.9	Good	Good	0	0	5.85	5.52	N/A	
SBC-CAT SECTOR 19 SRVC 21/22	35	71	Good		0	0	N/A	N/A	67	
SER-CAT SECTOR 22 CL130	50	60	Good		0	N/A	N/A	N/A	60	N/A
SGX-CAT SECTOR 31 SRVC 33/34	70	12.45	Good		0	N/A	N/A	N/A	N/A	
SECTOR 32 CL 160	160	N/A	Good		0	0	22.17	17.53	N/A	
UNI-CAT SECTOR 33 SRVC 35/36	120	N/A	Good		N/A	0	8.34	7.53	N/A	
SECTOR 34 CL 166	145	134	Good		N/A	0	N/A	15.92	N/A	