

# USER SKIDS ROUNDS

DATE: 5/30/03

TIME: \_\_\_\_\_

TECH: \_\_\_\_\_

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT <b>SECTOR 1</b> SRVC 3/4	120	N/A	Full	Good	0	1	N/A	17.01	N/A	
SRI-CAT <b>SECTOR 2</b> SRVC 5/6	Pressure @ PRV 90									
SRI-CAT <b>SECTOR 3/4</b> SRVC 7/8	120	56.4	Full	Good	0	0	11.09	11.64	N/A	
MU-CAT <b>SECTOR 6</b> CL 82	125	5.4	Full	Good	0	0	16.62	15.65	N/A	
MHATT-CAT <b>SECTOR 7</b> SRVC 9/10	85	N/A	Full		0	0	7.98	7.52	N/A	
IMM-CAT <b>SECTOR 8</b> CL 88	70	15.7	Full	Good	0	0	4.68	4.81	N/A	
CMC-CAT <b>SECTOR 9</b> SRVC 11/12	120	50	Full	Good	0	0	13.17	10.74	N/A	
BESSRC-CAT <b>SECTOR 11</b> SRVC 13/14	80	72.9	Full		0	N/A	N/A	N/A	N/A	
<b>SECTOR 13</b>	Pressure @ PRV 58									
<b>SECTOR 15</b> SRVC 17/18	80	27.5	Full	Good	0	0	6.69	6.63	N/A	
SBC-CAT <b>SECTOR 19</b> SRVC 21/22	55	71	Full		0	0	N/A	N/A	67	
SER-CAT <b>SECTOR 22</b> CL130	Pressure @ PRV 52									
<b>SECTOR 32</b> CL 160	160	N/A	Full		0	0	21.76	16.59	N/A	
UNI-CAT <b>SECTOR 33</b> SRVC 35/36	130	N/A	Full		N/A	0	7.65	7.44	N/A	
<b>SECTOR 34</b> CL 166	145	134			N/A	0	N/A	15.26	N/A	