

USER SKIDS ROUNDS

DATE:06/16/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		30.5								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 85	49.96								
SRI-CAT SECTOR 3 SRVC 7/8		22.7								
SRI-CAT SECTOR 4 SRVC 7/8		44.98								
MU-CAT SECTOR 6 CL 82	126	5.9	Good	Good	0	0	13.34	15.29	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	80	N/A	Good		0	0	5.44	5.36	N/A	
IMM-CAT SECTOR 8 CL 88		27.1								
MR-CAT SECTOR 10		26.6								
CMC-CAT SECTOR 9 SRVC 11/12	110	54.3	Good	na	0	0	8.33	7.05	N/A	
BESSRC-CAT SECTOR 11	80	72	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 69	19.1								
CARS-CAT SECTOR 14		10.1								
CARS-CAT SECTOR 15	80	27.4	Good	na	0	0	6.59	6.54	N/A	
HP-CAT SECTOR 16		47.4								
SECTOR 17		14.9								
SBC-CAT SECTOR 19 SRVC 21/22	70	72	Good		0	0	N/A	N/A	67	

SER-CAT SECTOR 22 CL130	Pressure @ PRV 49	18								
SGX-CAT SECTOR 31 SRVC 33/34		14.7								
SECTOR 32 CL 160	145	N/A	Good		0	0	22.04	17.36	N/A	
UNI-CAT SECTOR 33 SRVC 35/36		40.1								
SECTOR 34 CL 166		19.1								
Sector 23		15								
Sector 24		24.9								