

# USER SKIDS ROUNDS

DATE:6/18/03

TIME: \_\_\_\_\_

TECH: \_\_\_\_\_

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT <b>SECTOR 1</b> SRVC 3/4	115	N/A	Full	Good	0	1	N/A	16.43	N/A	
SRI-CAT <b>SECTOR 2</b> SRVC 5/6	Pressure @ PRV 90									
SRI-CAT <b>SECTOR 3/4</b> SRVC 7/8	130	60.1	Full	Good	0	0	14.29	14.77	N/A	
MU-CAT <b>SECTOR 6</b> CL 82	130	7.7	Full	Good	0	0	16.68	15.61	N/A	
MHATT-CAT <b>SECTOR 7</b> SRVC 9/10	90	N/A	Full		0	0	7.84	7.19	N/A	
IMM-CAT <b>SECTOR 8</b> CL 88	70	15.4	Full	Good	0	0	13.58	12.81	N/A	
CMC-CAT <b>SECTOR 9</b> SRVC 11/12	120	49.5	Full	Good	0	0	16.41	12.74	N/A	
BESSRC-CAT <b>SECTOR 11</b> SRVC 13/14	80	72	Full		0	N/A	N/A	N/A	N/A	
<b>SECTOR 13</b>	Pressure @ PRV 56									
<b>SECTOR 15</b> SRVC 17/18	80	27.5	Full	Good	0	0	6.97	6.89	N/A	
SBC-CAT <b>SECTOR 19</b> SRVC 21/22	55	72	Full		0	0	N/A	N/A	67	
SER-CAT <b>SECTOR 22</b> CL130	Pressure @ PRV 52									
<b>SECTOR 32</b> CL 160	165	N/A	Full		0	0	21.88	16.3	N/A	
UNI-CAT <b>SECTOR 33</b> SRVC 35/36	130	N/A	Full		N/A	0	7.07	7.34	N/A	
<b>SECTOR 34</b> CL 166	145	135			N/A	0	N/A	15.22	N/A	