

USER SKIDS ROUNDS

DATE:7/08/03

TIME: _____

TECH: _____

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4	115	N/A	Full	Good	0	1	N/A	15.64	N/A	
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 90									
SRI-CAT SECTOR 3/4 SRVC 7/8	135	56.7	Full	Good	0	0	12.72	13.24	N/A	
MU-CAT SECTOR 6 CL 82	130	7.6	Full	Good	0	0	13.52	14.39	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	85	N/A	Full		0	0	7.73	7.34	N/A	
IMM-CAT SECTOR 8 CL 88	70	15.3	Full	Good	0	0	13.17	13.16	N/A	
CMC-CAT SECTOR 9 SRVC 11/12	125	49.6	Full	Good	0	0	16.48	12.88	N/A	
BESSRC-CAT SECTOR 11 SRVC 13/14	80	72.9	Full		0	N/A	N/A	N/A	N/A	
SECTOR 13	Pressure @ PRV 60	17.5								
SECTOR 15 SRVC 17/18	75	27.7	Full	Good	0	0	7.17	6.89	N/A	
SBC-CAT SECTOR 19 SRVC 21/22	58	71	Full		0	0	N/A	N/A	67	
SER-CAT SECTOR 22 CL130	Pressure @ PRV 52	15.8								
SGX-CAT SECTOR 31 SRVC 33/34	Pressure @ PRV	15.7								
SECTOR 32 CL 160	160	N/A	Full		0	0	21.99	16.83	N/A	
UNI-CAT SECTOR 33 SRVC 35/36	130	N/A	Full		N/A	0	7.62	7.76	N/A	
SECTOR 34 CL 166	145	134			N/A	0	N/A	15.72	N/A	