

USER SKIDS ROUNDS

DATE:07/13/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		29.7								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 90	49.45								
SRI-CAT SECTOR 3 SRVC 7/8		17.8								
SRI-CAT SECTOR 4 SRVC 7/8		45.1								
MU-CAT SECTOR 6 CL 82	125	7.1	Good	Good	0	0	16.4	15.33	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	85	N/A	Good		0	0	6.57	5.99	N/A	
IMM-CAT SECTOR 8 CL 88		27.1								
MR-CAT SECTOR 10		26.7								
CMC-CAT SECTOR 9 SRVC 11/12	110	56.1	Good	na	0	0	8.1	6.52	N/A	
BESSRC-CAT SECTOR 11	80	72	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 65	19.2								
CARS-CAT SECTOR 14		9.9								
CARS-CAT SECTOR 15	80	27.2	Good	na	0	0	6.9	6.52	N/A	
HP-CAT SECTOR 16		47.4								
SECTOR 17		15								
SBC-CAT SECTOR 19 SRVC 21/22	37	67	Good		0	0	N/A	N/A	71	

SER-CAT SECTOR 22 CL130	Pressure @ PRV 50	15.8								
SGX-CAT SECTOR 31 SRVC 33/34		14.7								
SECTOR 32 CL 160	160	N/A	Good		0	0	22.6	16.92	N/A	
UNI-CAT SECTOR 33 SRVC 35/36		39.4								
SECTOR 34 CL 166		18.9								
Sector 23		14.7								
Sector 24		18.9								