

USER SKIDS ROUNDS

DATE:07/19/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		30								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 90	49.29								
SRI-CAT SECTOR 3 SRVC 7/8		17.9								
SRI-CAT SECTOR 4 SRVC 7/8		45.3								
MU-CAT SECTOR 6 CL 82	125	4.8	Good	Good	0	1	15.07	15.2	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	85	N/A	Good		0	0	6	5.72	N/A	
IMM-CAT SECTOR 8 CL 88		27.1								
MR-CAT SECTOR 10		26.3								
CMC-CAT SECTOR 9 SRVC 11/12	110	56.2	Good	na	0	0	7.31	6.41	N/A	
BESSRC-CAT SECTOR 11	79	72.9	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 60	20.3								
CARS-CAT SECTOR 14		8								
CARS-CAT SECTOR 15	80	27.2	Good	na	0	0	6.36	6.61	N/A	
HP-CAT SECTOR 16		47.6								
SECTOR 17		14.9								
SBC-CAT SECTOR 19 SRVC 21/22	75	71	Good		0	0	N/A	N/A	67	

SER-CAT SECTOR 22 CL130	Pressure @ PRV 50	13.7								
SGX-CAT SECTOR 31 SRVC 33/34		14.5								
SECTOR 32 CL 160	160	N/A	Good		0	0	23.26	17.39	N/A	
UNI-CAT SECTOR 33 SRVC 35/36		39.4								
SECTOR 34 CL 166		18.9								
Sector 23		14.6								
Sector 24		24.9								