

USER SKIDS ROUNDS

DATE:07/21/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		30								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 90	49.44								
SRI-CAT SECTOR 3 SRVC 7/8		17.7								
SRI-CAT SECTOR 4 SRVC 7/8		45.2								
MU-CAT SECTOR 6 CL 82	125	3.7	Good	Good	0	1	15.6	15.22	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	85	N/A	Good		0	0	6	5.78	N/A	
IMM-CAT SECTOR 8 CL 88		27.2								
MR-CAT SECTOR 10		26.2								
CMC-CAT SECTOR 9 SRVC 11/12	110	56.1	Good	na	0	0	7.53	6.24	N/A	
BESSRC-CAT SECTOR 11	80	72	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 63	18.4								
CARS-CAT SECTOR 14		9.9								
CARS-CAT SECTOR 15	80	26.9	Good	na	0	0	6.36	6.61	N/A	
HP-CAT SECTOR 16		47.4								
SECTOR 17		14.9								
SBC-CAT SECTOR 19 SRVC 21/22	75	71	Good		0	0	N/A	N/A	67	

SER-CAT SECTOR 22 CL130	Pressure @ PRV 59	17.8								
SGX-CAT SECTOR 31 SRVC 33/34		14.5								
SECTOR 32 CL 160	160	N/A	Good		0	0	22.98	17.53	N/A	
UNI-CAT SECTOR 33 SRVC 35/36		39.5								
SECTOR 34 CL 166		18.9								
Sector 23		14.6								
Sector 24		24.9								
sector 2	skid leaks	21.3					0.36	0.39		