

# USER SKIDS ROUNDS

DATE:7/30/03

TIME: \_\_\_\_\_

TECH: \_\_\_\_\_

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT <b>SECTOR 1</b> SRVC 3/4	118	N/A	Full	Good	0	1	N/A	17.19	N/A	
SRI-CAT <b>SECTOR 2</b> SRVC 5/6	Pressure @ PRV 90	38.8								
SRI-CAT <b>SECTOR 3/4</b> SRVC 7/8	140	56.9	Full	Good	0	0	15.86	14.79	N/A	
MU-CAT <b>SECTOR 6</b> CL 82	130	7.3	Full	Good	0	0	14.43	15.01	N/A	
MHATT-CAT <b>SECTOR 7</b> SRVC 9/10	80	N/A	Full		0	0	6.62	6.1	N/A	
IMM-CAT <b>SECTOR 8</b> CL 88	70	15.5	Full	Good	0	0	14.17	13.61	N/A	
CMC-CAT <b>SECTOR 9</b> SRVC 11/12	118	53.4	Full	Good	0	0	16.23	12.6	N/A	
BESSRC-CAT <b>SECTOR 11</b> SRVC 13/14	80	72	Full		0	N/A	N/A	N/A	N/A	
<b>SECTOR 13</b>	Pressure @ PRV 60	18.5								
<b>SECTOR 15</b> SRVC 17/18	80	27.8	Full	Good	0	0	10.37	10.17	N/A	
SBC-CAT <b>SECTOR 19</b> SRVC 21/22	40	70	Full		0	0	N/A	N/A	67	
SER-CAT <b>SECTOR 22</b> CL130	Pressure @ PRV 50	15.8								
SGX-CAT <b>SECTOR 31</b> SRVC 33/34	Pressure @ PRV	15.8								
<b>SECTOR 32</b> CL 160	160	N/A	Full		0	0	21.33	16.35	N/A	
UNI-CAT <b>SECTOR 33</b> SRVC 35/36	130	N/A	Full		0	0	5.08	4.97	N/A	
<b>SECTOR 34</b> CL 166	145	134			0	0	N/A	14.86	N/A	