

USER SKIDS ROUNDS

DATE:08/02/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		33.6								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 85	49.05								
SRI-CAT SECTOR 3 SRVC 7/8		18.1								
SRI-CAT SECTOR 4 SRVC 7/8		45.2								
MU-CAT SECTOR 6 CL 82	127	5.8	Good	Good	0	1	13.42	15.16	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	87	N/A	Good		0	0	6.16	5.79	N/A	
IMM-CAT SECTOR 8 CL 88		27.2								
MR-CAT SECTOR 10		26.5								
CMC-CAT SECTOR 9 SRVC 11/12	110	56	Good	na	0	0	7.11	6.14	N/A	
BESSRC-CAT SECTOR 11	80	72.9	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 62	21								
CARS-CAT SECTOR 14		10.1								
CARS-CAT SECTOR 15	80	27.2	Good	na	0	0	9.52	9.81	N/A	
HP-CAT SECTOR 16		47.5								
SECTOR 17		14.9								
SBC-CAT SECTOR 19 SRVC 21/22	72	72	Good		0	0	N/A	N/A	67	

SER-CAT SECTOR 22 CL130	Pressure @ PRV 48	18								
SGX-CAT SECTOR 31 SRVC 33/34		14.7								
SECTOR 32 CL 160	165	N/A	Good		0	0	24.08	18.03	N/A	
UNI-CAT SECTOR 33 SRVC 35/36		40.3								
SECTOR 34 CL 166		19								
Sector 23		14.6								
Sector 24		25								
sector 2	6.5	21.1						1.03		