

# USER SKIDS ROUNDS

DATE:8/09/03

TIME: \_\_\_\_\_

TECH: \_\_\_\_\_

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT <b>SECTOR 1</b> SRVC 3/4	115	N/A	Full	Good	0	1	N/A	16.42	N/A	
SRI-CAT <b>SECTOR 2</b> SRVC 5/6	Pressure @ PRV 90	38.72								
SRI-CAT <b>SECTOR 3/4</b> SRVC 7/8	140	56.9	Full	Good	0	0	14.94	14.63	N/A	
MU-CAT <b>SECTOR 6</b> CL 82	130	7.3	Full	Good	0	0	8.64	8.96	N/A	
MHATT-CAT <b>SECTOR 7</b> SRVC 9/10	82	N/A	Full		0	0	5.67	5.36	N/A	
IMM-CAT <b>SECTOR 8</b> CL 88	70	15.5	Full	Good	0	0	9.79	10	N/A	
CMC-CAT <b>SECTOR 9</b> SRVC 11/12	115	54.7	Full	Good	0	0	15.26	12.38	N/A	
BESSRC-CAT <b>SECTOR 11</b> SRVC 13/14	80	72.9	Full		0	N/A	N/A	N/A	N/A	
<b>SECTOR 13</b>	Pressure @ PRV 60	18.4								
<b>SECTOR 15</b> SRVC 17/18	80	27.6	Full	Good	0	0	7.95	7.96	N/A	
SBC-CAT <b>SECTOR 19</b> SRVC 21/22	40	71	Full		0	0	N/A	N/A	67	
SER-CAT <b>SECTOR 22</b> CL130	Pressure @ PRV 52	16								
SGX-CAT <b>SECTOR 31</b> SRVC 33/34	Pressure @ PRV	15.8								
<b>SECTOR 32</b> CL 160	160	N/A	Full		0	0	21.87	16.88	N/A	
UNI-CAT <b>SECTOR 33</b> SRVC 35/36	135	N/A	Full		0	0	4.6	4.6	N/A	
<b>SECTOR 34</b> CL 166	145	134			0	0	N/A	14.71	N/A	