

USER SKIDS ROUNDS

DATE:10/01/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		28.9								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 85	48.73								
SRI-CAT SECTOR 3 SRVC 7/8		17.6								
SRI-CAT SECTOR 4 SRVC 7/8		45.4								
MU-CAT SECTOR 6 CL 82	130	5.1	Good	Good	0	1	15.03	15.14	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10		31.7								
IMM-CAT SECTOR 8 CL 88		26.8								
MR-CAT SECTOR 10		26.3								
CMC-CAT SECTOR 9 SRVC 11/12	110	56	Good	na	0	0	6.26	5.3	N/A	
BESSRC-CAT SECTOR 11	80	75	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 70	17.4								
CARS-CAT SECTOR 14		10.2								
CARS-CAT SECTOR 15	70	26.7	Good	na	0	0	10.65	10.32	N/A	
HP-CAT SECTOR 16		42								
SECTOR 17		15.1								
SBC-CAT SECTOR 19 SRVC 21/22	30	71	Good		0	0	N/A	N/A	67	

