

USER SKIDS ROUNDS

DATE:10/07/04

TIME: _____

TECH: DC DB

CAT NAME/ LOCATION	PUMP DISCHARGE OR SYSTEM PRESSURE	SYSTEM FLOW RATE	SYSTEM LEVEL/ FILL	N2 PRESSURE	SYSTEM FILTER DP	POLISHING FILTER DP	POLISHING RESISTIVITY	SYSTEM RESISTIVITY	SUPPLY TEMP.	UV
SRI-CAT SECTOR 1 SRVC 3/4		32.5								
SRI-CAT SECTOR 2 SRVC 5/6	Pressure @ PRV 90	47.95								
SRI-CAT SECTOR 3 SRVC 7/8		17.74								
SRI-CAT SECTOR 4 SRVC 7/8		45.7								
MU-CAT SECTOR 6 CL 82	130	5.5	Good	Good	0	1	14.64	15.44	N/A	
MHATT-CAT SECTOR 7 SRVC 9/10	110	31.5								
IMM-CAT SECTOR 8 CL 88		26.8								
MR-CAT SECTOR 10		26.2								
CMC-CAT SECTOR 9 SRVC 11/12	110	56.2	Good	na	0	0	5.88	5.17	N/A	
BESSRC-CAT SECTOR 11	80	75	Good		0	N/A	N/A	N/A	N/A	
CARS-CAT SECTOR 13	Pressure @ PRV 70	21.6								
CARS-CAT SECTOR 14		10.1								
CARS-CAT SECTOR 15	79	26.7	Good	na	0	0	10.3	10.38	N/A	
HP-CAT SECTOR 16		43.2								
SECTOR 17		15.1								
SBC-CAT SECTOR 19 SRVC 21/22	30	71	Good		0	0	N/A	N/A	67	

