

USER BEAMLINE FLOWMETERS

USER BEAMLINE	Flowmeter	Flowmeter range		Transmitter calibration	
	Serial No.	LOW	HIGH	LOW	HIGH
		(gpm)	(gpm)	(inches w.c.)	(inches w.c.)
1	<a href="#">02-1913</a>	0	48	0	327.27
2	<a href="#">02-2258</a>	0	48	0	347.9
3	<a href="#">02-2256</a>	0	48	0	343.26
4	<a href="#">02-2253</a>	0	48	0	340.57
5					
6					
7	03-3270				
8	<a href="#">02-1910</a>	0	48	0	321.75
9	<a href="#">02-1911</a>	0	48	0	330.31
10	<a href="#">02-2259</a>	0	48	0	348.98
11	<a href="#">02-2257</a>	0	48	0	350.36
12					
13	<a href="#">02-2255</a>	0	48	0	346.19
14	<a href="#">02-0437</a>	0	48	0	333.31
15					
16	<a href="#">02-0445</a>	0	48	0	328.87
17	<a href="#">02-0446</a>	0	48	0	326.16
18					
19					
20	<a href="#">03-0751</a>				
21					
22 (SUPPLY)	<a href="#">02-1912</a>	0	48	0	329.47
22 (RETURN)	<a href="#">02-2254</a>	0	48	0	262.12
23	<a href="#">03-2180</a>	0	48	0	354.38
24	<a href="#">03-1702</a>				
25	<a href="#">03-3272</a>				
26	<a href="#">03-2180</a>				
27					
28					
29					
30	<a href="#">99-0581</a>				
30 (CHILLED)	<a href="#">99-0582</a>				
31	<a href="#">02-2252</a>	0	48	0	340.01
32					
33	<a href="#">03-1700</a>	0	48	0	363.52
34	<a href="#">03-2179</a>	0	48	0	350.69