

file name: 94100110

sized: 10/28/1994

meter identification: 94100110 tag:
 application customer: ARGONNE LABS
 V-Cone model number: V000B-AL

fluid: Water/water

comments: _____

fluid boiling point: 671.800 R

Operating Conditions:

temperature: 75.000 F
 pressure: 150.000 psig
 fluid mass: 62.098#/ft3
 viscosity: 0.834 cP
 Z-factor: 0.003

CERTIFIED: <u>Jan</u>

Meter Specifications:

inside diameter: 0.656in
 cone diameter: 0.468in
 beta ratio: 0.7007
 Fa: 1.0001

turndown: 10.0 to 1 Cf: 0.8100
 - Cf is linear to flowrate -

FLOWRATE (GPM)	DIFF-PRESS (inWC)	VELOCITY (f/s)	REYNOLDS NUMBER	COEFFICIENT OF FLOW
8.0000	51.309	7.59	45927.	0.81000
6.9022	38.193	6.55	39625.	0.81000
6.3925	32.761	6.07	36699.	0.81000
5.9720	28.592	5.67	34285.	0.81000
5.5929	25.078	5.31	32109.	0.81000
5.2363	21.982	4.97	30061.	0.81000
4.8916	19.183	4.64	28082.	0.81000
4.5516	16.609	4.32	26130.	0.81000
4.2105	14.213	4.00	24172.	0.81000
3.8628	11.963	3.67	22176.	0.81000
3.5024	9.8343	3.32	20107.	0.81000
3.1212	7.8099	2.96	17918.	0.81000
2.7072	5.8757	2.57	15542.	0.81000
2.2394	4.0205	2.13	12856.	0.81000
1.6698	2.2354	1.58	9586.4	0.81000
0.79997	0.51304	0.759	4592.5	0.81000

sized by: Cowley Parker, 10/28/94, approval: _____