

file name:94100150

sized:11/30/1994

meter identification: 94100150 tag:
 application customer: ARGONNE LABS
 V-Cone model number: V000B-AL

fluid: Water/water comments: _____

fluid boiling point: 671.800 R

Operating Conditions:
 temperature: 75.000 F
 pressure: 150.000 psiG
 fluid mass: 62.098#/ft3
 viscosity: 0.834 cP
 Z-factor: 0.003

CERTIFIED: Jan

Meter Specifications:
 inside diameter: 0.656in
 cone diameter: 0.419in
 beta ratio: 0.7694
 Fa: 1.0001

turndown: 10.0to1 Cf: 0.7910
 - Cf is linear to flowrate -

FLOWRATE (GPM)	DIFF-PRESS (inWC)	VELOCITY (f/s)	REYNOLDS NUMBER	COEFFICIENT OF FLOW
10.000	49.495	9.49	57409.	0.79100
8.6278	36.843	8.19	49531.	0.79100
7.9906	31.603	7.58	45874.	0.79100
7.4650	27.582	7.08	42856.	0.79100
6.9912	24.192	6.64	40136.	0.79100
6.5454	21.205	6.21	37577.	0.79100
6.1145	18.505	5.80	35103.	0.79100
5.6895	16.022	5.40	32663.	0.79100
5.2631	13.710	5.00	30215.	0.79100
4.8285	11.540	4.58	27720.	0.79100
4.3780	9.4867	4.16	25134.	0.79100
3.9015	7.5339	3.70	22398.	0.79100
3.3840	5.6680	3.21	19427.	0.79100
2.7993	3.8784	2.66	16070.	0.79100
2.0873	2.1564	1.98	11983.	0.79100
0.99996	0.49491	0.949	5740.7	0.79100

sized by Carolyn Jaker, 11/30/94, approval: _____, _____