

file name: 94100221

sized: 11/11/1994

meter identification: 94100221 tag:
 application customer: ARGONNE LABS
 V-Cone model number: V000A - A L

fluid: Water/water

comments: _____

fluid boiling point: 671.800 R

Operating Conditions:

temperature: 75.000 F
 pressure: 150.000 psig
 fluid mass: 62.098#/ft³
 viscosity: 0.834 cP
 Z-factor: 0.003

CERTIFIED: JAM

Meter Specifications:

inside diameter: 0.438in
 cone diameter: 0.299in
 beta ratio: 0.7307
 Fa: 1.0001

turndown: 10.0to1 Cf: 0.7650
 - Cf is linear to flowrate -

FLOWRATE (GPM)	DIFF-PRESS (inWC)	VELOCITY (f/s)	REYNOLDS NUMBER	COEFFICIENT OF FLOW
4.0002	57.642	8.52	34394.	0.76500
3.4512	42.908	7.35	29675.	0.76500
3.1964	36.805	6.80	27483.	0.76500
2.9861	32.122	6.36	25675.	0.76500
2.7966	28.173	5.95	24046.	0.76500
2.6183	24.695	5.57	22512.	0.76500
2.4459	21.551	5.21	21030.	0.76500
2.2759	18.659	4.85	19569.	0.76500
2.1053	15.967	4.48	18102.	0.76500
1.9315	13.439	4.11	16607.	0.76500
1.7513	11.048	3.73	15058.	0.76500
1.5606	8.7739	3.32	13419.	0.76500
1.3537	6.6010	2.88	11639.	0.76500
1.1198	4.5168	2.38	9627.9	0.76500
0.83495	2.5114	1.78	7179.1	0.76500
0.40000	0.57637	0.852	3439.3	0.76500

sized by: Cauly Parker, 11/11/94 approval: _____