



PANEL MATERIAL			
DEVICE TAG	QTY	CODE NUMBER	DESCRIPTION
EN-31006	1	EN-BSF201-0	2 SLOT BASE FRAME
	1	EN-EVC200-0	NCL/NEU 16X30 ENCLOSURE
	1	IQ-NTU102-0	NETWORK TERMINAL W/LIGHT
	1	IQ-NTU114-0	REMOTE LINE DRIVER
	8	FM-IUN102-0	UNIVERSAL INPUT FM
LI-1-LI-7, LI-10			
LI-7-LI-9	3	FM-IUN101-0	
LD-1, LD-3, LD-5, LD-7	4	FM-DAP121-0	E/P OUTPUT FM F/DCM 1SL0T
LD-2, LD-4, LD-6, LD-8-LD-10	2	FM-KIT127-0	FM BLANKOFFS
	4	FM-DRL101-0	LATCH RELAY OUTPUT FM
NU-1	1	NU-DCM140-0	DIGITAL CONTROL MODULE
NU-2	1	NU-XRL101-0	XH-B/OUT LATCH B/INP
PS-1-PS-2	2	NU-PWR101-0	POWER SUPPLY

Enclosure, EN-31006, NEU Serving Building 420
Process Water(RF-EXT-West)

FILE: EN-31006

DRAWING TITLE		Enclosure, EN-31006	
PROJECT		The Argonne National Labs Advanced Photon Source Campus 9700 Cass Avenue South Argonne, IL 60439	
SALES ENGR	PROJECT MGR	APPL ENGR	DRAWN
JP	SF	DCS	BY SF
REVISION-LOCATION		ECN DATE BY	
NO.		APPROVED	
DATE 11/19/94		DATE	
3007 MALMO ROAD ARLINGTON HEIGHTS ILLINOIS 60005 708/364-1500 Main 708/806-4438 Eng		CONTRACT NUMBER 91390-0009	
JOHNSON CONTROLS Systems & Services Division		DRAWING NUMBER 91-9-D-02G	